

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

Insul-Quilts, Inc.
1432 Chico Avenue
South El Monte, CA 91733

Attn: Roy Tonks
(626) 575-1973

RESEARCH REPORT: RR 22713
(CSI 07200)

Expires: April 1, 2012
Issued Date: March 1, 2010
Code: 2008 LABC

GENERAL APPROVAL – Renewal - G. F. Insul-Quilt.

DETAILS

G. F. Insul-Quilt is approved as an interior finish material with a flame spread rating of three and a smoke density of zero (ASTM E-84).

G. F. Insul-Quilt is a sound absorbent material consisting of mineral fiber 2" thick with a density of 4 lbs./cu. ft. The mineral fiber is faced one side with 0.003" fiberglass cloth and on the other face with 0.008" aluminum and paper laminate.

Insul-Quilts is approved by the City of Los Angeles with RR 7697 for installation in a Plenum and meets the requirement for use in Plenum under section 95.105.0 and 95.6052.0 of the 2008 Los Angeles Mechanical Code.

RR 22713
Page 1 of 2

Insul-Quilts, Inc.
RE: G.F. Insul-Quilt


DISCUSSION

The report is in compliance with 2008 Los Angeles Building Code.

The report is based on tests. Test reports, details and other pertinent data on file in the office of the Engineering Research Section.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.



YEUAN CHOU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9812
Fax - 213-202-9943

W YC:elcm
RR22713/MSW3
R03/05/10
4D2/4B1/1208